

RECALL SAFETY NOTICE

Risk: Fire Hazard

Potential damage from overheating and fire to appliances or other equipment



Square D QO™ Plug-On Neutral Loadcentres also known as Loadcentres, Breaker Boxes, Electric Panels

Manufactured February 2020 – January 2022



Indoor Loadcentre



Outdoor Loadcentre

Within affected QO Plug-On Neutral Loadcentres, the wire binding screw may not be fully tightened to the neutral bar.
Free inspection and repair for recalled product shall be provided.

For more information contact Schneider Electric Customer Care.

- By phone at 1-888-778-2733; option 2,1,4 from 8AM-5PM EST
- Chat <https://www.se.com/us/en/work/support/customer-care/contact-schneider-electric.jsp>
- Visit: <https://se.com/us/qoloadcenter-safetynotice>

Post until September 30, 2022

In cooperation with Health Canada